

Boiler Water Treatment Principles and Practice: Charts and Notes for Field Use

Boiler Water Treatment Principles and Practice: Charts and Notes for Field Use

© 2013 Chemical Publishing Co., Inc. All rights reserved.

No part of this publication may be reproduced, stored in a retrieval system or transmitted in any form or by any means, electronic, mechanical, photocopying, recording, scanning or otherwise, except as permitted under Sections 107 or 108 of the 1976 United States Copyright Act, without either the prior written permission of the Publisher, or authorization through payment of the appropriate per-copy fee to the Copyright Clearance Center, 222 Rosewood Drive, Danvers, MA 01923, or on the web at www.copyright.com. Requests to the Publisher for permission should be addressed to the Publisher, Chemical Publishing Company, through email at info@chemical-publishing.com.

The publisher and the author make no representations or warranties with respect to the accuracy or completeness of the contents of this work and specifically disclaim all warranties, including without limitation warranties of fitness for a particular purpose.

ISBN: 978-0-8206-0173-1

First Edition:

Chemical Publishing Company, Inc. – 2013

Chemical Publishing Company:

www.chemical-publishing.com

Printed in the United States of America

Table of Contents

| | |
|---|-----|
| About the Author | vii |
| Saturated steam temperatures at various boiler pressures | 2 |
| Boiler Energy and Power Units | 2 |
| Typical gross heating values of common fuels (based on approximately 80% fuel to steam efficiency) | 3 |
| Typical energy consumption and output ratings for a fire tube boiler | 4 |
| Steam tables suitable for pressure deaerators | 5 |
| Calculating Blowdown | 6 |
| Coefficients of thermal conductivity for some heat-exchanger metals and boiler deposits | 6 |
| Types of water or steam commonly employed in most HW heating and steam generating plants | 7 |
| Commonly occurring minerals in natural MU water sources | 8 |
| Specific waterside/steamside problems affecting MPH and HPHW boiler plants | 8 |
| Salt concentration indicators | 9 |

| | |
|--|----|
| Summary of waterside/steamside problems affecting LPHW and LP steam heating boiler plants | 10 |
| FW contamination from MU water | 11 |
| FW contamination from returned condensate | 12 |
| Problems associated with the final FW blend | 13 |
| Deposition of boiler section waterside surfaces by alkaline earth metal salts, other inorganic salts and organics | 14 |
| Silica and silicate crystalline scales and deposits affecting boiler section waterside surfaces | 15 |
| Iron oxide and other boiler section corrosion debris deposits | 16 |
| Boiler section corrosion problems involving oxygen, concentration cells and low pH | 17 |
| Stress and high temperature related corrosion | 18 |
| Steam purity, quality and other operational problems | 19 |
| Specification for grades of high-quality water suitable for higher pressure WT boilers | 20 |
| Practical considerations for a RW ion-exchange softener | 20 |
| Types of Internal Treatment Program | 21 |
| Carbonate Cycle Requirement Calculations | 24 |
| Phosphate-Cycle Requirement Calculations | 25 |
| A Guide to Tannin Residuals in BW | 25 |
| Carbonate-Cycle Program. BW Carbonate Reserve Requirements by Pressure and Sulfate Concentration | 26 |
| Carbonate-Cycle Coagulation and Precipitation Program. Recommended BW Control Limits for Non-Highly-Rated FT Boilers Employing Hard or Partially Softened FW | 26 |

| | |
|--|----|
| Phosphate-Cycle Coagulation and Precipitation Program. Recommended BW Control Limits for Non-Highly-Rated FT Boilers Employing Hard, Partially Softened, or Fully Softened FW | 27 |
| Phosphate-Cycle Coagulation and Precipitation Program. Recommended BW Control Limits for Non-Highly-Rated WT Boilers Employing Hard, Partially Softened, or Fully Softened FW | 27 |
| Chelant demand (ppm product) per 1ppm substrate | 28 |
| EDTA Chelant or All-Polymer/All-Organic Program. Recommended BW Control Limits for Fired WT Boilers Employing Demineralized or Similar Quality FW | 29 |
| Oxygen Solubility at Atmospheric Pressure | 30 |
| Properties of Oxygen Scavengers | 31 |
| Carbon Dioxide Evolution from FW Alkalinity | 32 |
| Amine Requirement to Reach a Stable Condensate pH | 32 |
| Amine Basicity Dissociation Constants | 32 |
| Neutralizing Amine Summary Notes | 33 |
| Some DR values for CO ₂ , NH ₃ and neutralizing amines at various pressures | 34 |
| Calculating Alkalinity Feed-Rate Requirements | 35 |
| ASME Consensus table 1: Suggested water chemistry limits. Industrial watertube, high duty, primary fuel fired, drum type Makeup water percentage: Up to 100% of feedwater. Conditions: Includes superheater, turbine drives or process restriction on steam purity | 38 |
| ASME Consensus table 2: Suggested chemistry limits. Industrial watertube, high duty, primary fuel fired, drum type | 40 |

| | |
|--|----|
| ASME Consensus table 3: Suggested chemistry limits. Industrial firetube, high duty, primary fuel fired | 41 |
| ASME Consensus table 4: Suggested water chemistry limits. Industrial coil type, watertube, high duty, primary fuel fired rapid steam generators | 42 |
| ASME Consensus table 5: Suggested water chemistry limits. Marine propulsion, watertube, oil fired drum type | 44 |
| ASME Consensus table 6: Suggested water chemistry limits. Electrode, high voltage, forced circulation jet type | 45 |
| Reduction in heat transfer efficiency with increase in deposit thickness, where A = iron oxides and silica, B = iron oxides, C = calcium carbonate | 46 |
| Notes | 47 |

About the Author

Colin Frayne, CSci, CChem, CEnv, CWEM, FRSC, FICorr, MCIWEM, MWMSoc (UK), CWT (USA), is an international water treatment consultant and small business owner.

He has more than 45 years of experience in the practice of industrial chemistry and industrial water systems management, and has worked and lectured in over 50 countries. During those years he has also lived on four continents, with his family, while being variously employed in Q.C. and R&D laboratories, in technical sales, sales management, marketing, training, international business development, import/export, and general management.

He graduated in analytical chemistry from North London Polytechnic (now the University of North London), in the United Kingdom, and later obtained various business diplomas from colleges in the U.K. and South Africa, including Wits Business School in Johannesburg.

In November 2004, Colin was presented with the Association of Water Technologies, Ray Baum Memorial Award, as “Water Technologist of the Year”.

Mr. Frayne holds dual nationality (Britain/USA) and currently lives in Georgia (after spells in New York city and Florida), where he continues to undertake technology, marketing, and business consulting services work throughout the U.S. and internationally, via his small private company – “Aquassurance, Inc.”

He can be reached on +1-561-267-4381,
or by email: aquassurance@msn.com

